



America

# CERTIFICATE

No. U8 16 01 80346 014

**Holder of Certificate:** **Fortress Interlocks Ltd**

2 Inverclyde Drive  
 Wolverhampton  
 West Midlands WV4 6FB  
 UNITED KINGDOM

**Production Facility(ies):** 80346

**Certification Mark:**



**Product:** **Safety components Control Units**

**Model(s):** **amGardncs**

**Parameters:**  
 Rated voltage 24V +10%/-15% DC  
 Rated current 200mA

**Tested according to:**  
 UL 508:1999/R:2013-10  
 CAN/CSA-C22.2 No. 14-13:2013-03  
 Supplemented by:  
 UL 60947-5-1:2014-03  
 CAN/CSA-C22.2 No. 60947-5-1:2014-01

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in anyway. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC Guide 67. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

**Test report no.:** 028-713071963-000

**Date,** 2016-01-18

Page 1 of 1

