



Product Service

CERTIFICATE

No. Z10 15 10 80346 007

Holder of Certificate: Fortress Interlocks Ltd
2 Inverclyde Drive
Wolverhampton
West Midlands WV4 6FB
UNITED KINGDOM

Factory(ies): 80346

Certification Mark:



Product: Safety components
Safety Interlocks

Model(s): tGard
For nomenclature see attachment
Nomenclature

Parameters:

Ambient Temperature:	0°C to +40°C (solenoids) 0°C to +60°C (switches and bodies)
Maximum Relative Humidity:	93(+/-3)% without any dew on the device
Ingress Protection:	IP65

Tested according to: EN ISO 13849-1:2008 (Cat. 3 PL d)
EN ISO 13849-2:2012
ISO 14119:2013

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: FW86384T

Valid until: 2020-10-27

Date, 2015-10-28 (Matthias Ramold)



Page 1 of 7